


SUPERIOR TO UTILIZE 1/2" HARDWARE AND WILL FASTEN TO HOUSE FRAME

AGITATOR
0.33HP, 1750 RPM, 3/60/460V TEFC

CONNECTION TABLE LIST		
CONNECTION NUMBER	CONNECTION SIZE & TYPE	CONNECTION NAME
T8200	2" 150# FF FLANGE, PVC	TANK ADDITION CONNECTION
T8150	2" 150# FF FLANGE, PVC	TANK ADDITION CONNECTION
T8220	2" 150# FF FLANGE, PVC	TANK ADDITION CONNECTION
T8201	2" QUICK CONNECT COUPLING	TANK FILL
T8111	2" QUICK CONNECT COUPLING	TANK FILL
T8221	2" QUICK CONNECT COUPLING	TANK FILL
T8202	3" 600# RF FLANGE, 316SS	DISCHARGE, 62-PU-002
T8203	3" 600# RF FLANGE, 316SS	DISCHARGE, 62-PU-002
T8213	3" 150# RF FLANGE, 316SS	DISCHARGE, 62-PU-003
T8222	3" 150# RF FLANGE, 316SS	DISCHARGE, 62-PU-004
T8204/T8213/T8223	2" 150# FF FLANGE, PVC	TANK DRAIN CONNECTION
1	2" TYP	DRIP PAN DRAIN



- NOTES:**
- UNLESS OTHERWISE SPECIFIED ALL DIMENSIONS ARE IN INCHES. DIMENSIONS IN BRACKETS INDICATE MILLIMETERS.
 - DIMENSIONS ENCLOSED WITH PARENTHESES INDICATE REFERENCE.
 - ALL FRAME MATERIAL A-36 CARBON STEEL HOT DIPPED GALVANIZED COATING.
 - SEE PID FOR PIPE MATERIALS.
 - ALLOW 12" CLEARANCE ON THE TOP & ALL SIDES FOR MAINTENANCE ACCESS, UNLESS NOTED OTHERWISE.
 - APPROXIMATE SKID WEIGHT:
DRY: 4,673 LBS
OPERATING: 6,723 LBS
 - PIPE CONNECTIONS +/- 1" IN ALL DIMENSIONS.
 - DO NOT SCALE DRAWING.

NALCO BT-2600, NALCO ELIMI-NOX, TRI-ACT 1800

SUPERIOR INDUSTRIAL EQUIPMENT
C13314-201-PAGE 1 of 3 82-PU-002, 003, 004

REV	DESCRIPTION	BY	CHK'D	DATE
4	REVISED	SV	GM	04/14/14
1	REVISED	SV	GM	03/24/14
2	UPDATED PER CUSTOMER REQUEST	SV	GM	02/13/14
1	RELEASED FOR APPROVAL	SV	GM	01/03/14

THIS DOCUMENT IS PROPERTY OF SUPERIOR INDUSTRIAL EQUIPMENT. IT IS TO BE KEPT IN CONFIDENCE AND NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM.

FOR APPROVAL - SIGNATURE

Acceptance Status Code	Design/Calculation	Checker	Signature	Date
AC	Approved	X. Summers		

FOR APPROVAL - SIGNATURE

Acceptance Status Code	Design/Calculation	Checker	Signature	Date
AC	Approved	X. Summers		

FOR APPROVAL - SIGNATURE

Acceptance Status Code	Design/Calculation	Checker	Signature	Date
AC	Approved	X. Summers		

REV	DESCRIPTION	BY	CHK'D	DATE
5	FINAL REVISION	SV	GM	05/25/14
1	ISSUED FOR CONSTRUCTION	SV	GM	05/25/14